

April 18, 2023

BHL Group, LLC
977 Seminole Trail #292
Charlottesville, VA 22901

RE: Site and Soil Evaluation For Proposed Septic System
Old Cabin Road, Cascade VA – Pittsylvania County
Tax Map# 1366-90-5091; 5.01 Acres

Dear Mr. Legg,

At your request, I have evaluated the site and soil conditions at the above referenced property for the ability to install an onsite sewage disposal system. The site has been evaluated based upon current Virginia Department of Health Regulations.


My evaluation indicates that the site and soils are suitable for the installation of “conventional” drainfield. This assumes a maximum daily flow of 600 GPD (4 Bedrooms).

It is advised that the VDH would be the regulation agency on this property and would issue the final approval on any design that utilized these onsite soils.

This information does not serve as permission to construct a septic system. A formal permit design package can be prepared at your request and must be approved by the local health department prior to construction.

Hill Environmental & Engineering Services, PLLC. appreciates the opportunity to serve as your soil consultant on this project. Please do not hesitate to contact me if you have any questions regarding this letter.

Sincerely,



Shannon D. Hill; LPSS, AOSE
Licensed Professional Soil Scientist/Alternative Onsite Soil Evaluator